



NOTES

- 1 : FLAME PROOF GROUPS : IIA & IIB AS PER IS 2148/1981
- 2 . DEGREE OF PROTECTION IP65 AS PER IS:2147/1962.
- 3 : MATERIAL - CAST ALUMINIUM ALLOY LM6
- 4 : GASKET - NEOPRENE
- 5 : EARTHING - 1 No. INTERNAL & 2 Nos. EXTERNAL SCREWS ARE PROVIDED
- 6 : FINISH - LIGHT GREY TO SHADE 631 OF ISS (EPOXY POWDER COATED)
- 7 : ALL INTERCONNECTION BY Cu. WIRE WITH PVC INSULATED.
- 8 : TERMINAL BLOCK -
 - I/C : 3 Nos. 25 Sq.mm
 - D/G : 6 Nos. 16 Sq.mm
- 9 : CABLE ENTRY - 3 Nos. 1" ET
 - 1 No. 3/4" ET ENTRY

ELEVATION

SIDE VIEW

- 9 : I/C - 63A TP ISOLATOR
- 3 Nos. 32A CONTACTOR
- 1 No. BMR (16-25A)
- 1 No. STAR/DELTA TIMER
- 1 SET OF START/STOP PUSH BUTTON WITH IND+INC CONTACT
- STOP PB STAYPUT TYPE, PRESS TO LOCK AND TURN TO RELEASE

OVERALL DIMENSIONS ±10mm

P. O. No.	---	CUSTOMER	CMRI CERT NO.	CMRI/TC/P/H871 DT.09.07.99.	PROJECT	CMRI/TC/H721 DT.21.05.097	CONSULTANT	DRN	SM	TITLE:	FLP-WP 50HP STAR/DELTA STARTER				
CAT REF:	99186.1005							CHKD	DKK	CAD REF	DRG.ND:	SCG/DF0000/DLL1001/0001	SHT.ND	RE V.	DATE
DA No. :	-----							APRD	GK	DLL/1001		1 DF 1	0		14/11/05
								SCALE	NTS						



SCG Ex-d TECH PVT. LTD., CHENNAI - 600 032.