



NOTES

- 1 : FLAME PROOF GROUPS - IIA & IIB AS PER IS 2148/1981
- 2 : MATERIAL - CAST ALUMINIUM ALLOY LMS
- 3 : FINISH - LIGHT GREY TO SHADE 631 OF ISS
- 4 : EARTHING - 1 INTERNAL & 2 EXTERNAL SCREWS ARE PROVIDED
- 5 : DEGREE OF PROTECTION - IP65 AS PER IS2147/1962.
- 6 : GASKET - NEOPRENE
- 7 : ALL INTERCONNECTION BY SOLID Cu. / Cu. WIRE WITH PVC INSULATED.
- 8 : TERMINAL BLOCKS - -----
- 9 : CABLE ENTRY - 1/2" - 1 1/2" ET-2 Nos. FOR 3 1/2" 70 Sqmm Cu. CABLE
D/G - 2" ET - 2 Nos. FOR 3 1/2" 150Sqmm CABLE
CONTROL - 2 Nos. 3/4" ET

ELEVATION

- 10 : OTHER DETAILS
 - 1 No. 250A TP SFU (I/C)
 - 3 Nos. 250A HRC FUSE
 - 2 Nos. 140A CONTACTOR
 - 1 No. 110A CONTACTOR
 - 1 No. TIMER
 - 1 No. 415/230V, 750VA CONTROL TRANSFORMER
 - 1 No. 72SQMM AMMETER WITH SELECTOR SWITCH
 - 1 No. 72SQMM VOLTMEETER WITH SELECTOR SWITCH

SIDE VIEW

- 1 SET OF START/STOP PUSH BUTTON
(STOP PB WITH PUSH TO LOCK TURN TO RELEASE)
- 2 Nos. INDICATING LAMP

SPECIAL NOTE:-

HIGHER RATING OF STAR/ DELTA STARTER WITH AMMETER & VOLTMEETER

OVERALL DIMENTION ±10mm

| | | | | | | | |
|-----------------|---------------|-----------------------------|--|----------------|------|----------|---|
| P. O. No. ----- | CMRI CERT NO. | CUSTOMER PROJECT CONSULTANT | NUTECH JETTING EQUIPMENTS INDIA (P) LTD. | DRN | SM | TITLE: | FLP-WP 110KW (150 HP) STAR/DELTA STARTER |
| | CMRI/TC/H791 | | | DATE 10.07.96. | CHKD | | |
| CAT REF: 1001 | | | | APRD | GK | SCALE | DRG.ND: |
| OA NO. : ----- | | | | | | CAD REF | SCG/DF/0000/DLL1001/0001 |
| | | | | | | DLL/1001 | 1 OF 1 |
| | | | | | | | SHT.ND |
| | | | | | | | REV. |
| | | | | | | | DATE |
| | | | | | | | 14/11/05 |



SCG Ex d TECH PVT. LTD., CHENNAI - 600 032.