



NOTES:-

- 1 : FLAMEPROOF GROUPS- IIA & IIB AS PER IS:2148/1981.
- 2 : DEGREE OF PROTECTION - IP 55 AS PER IS:2147/1962
- 3 : MATERIAL - CAST ALUMINIUM ALLOY LM6
- 4 : EARTHING - 1 No. INTERNAL & 2 Nos. EXTERNAL (LM6)
- 5 : HARDWARE - M.S. GALVANISED HIGH TENSILE
- 6 : SCG MAKE STUD TYPE TERMINAL WILL BE PROVIDED
- 7 : CABLE ENTRY - 3 Nos. 3/4" ET AT BOTTOM SIDE

OVERALL DIMENSION ARE $\pm 10\text{mm}$

CUSTOMER		TITLE				
PROJECT		FLAMEPROOF CUM INTRINSICALLY SAFE PUSH BUTTON OPERATED TELEPHONE				
CONSULTANT		SCG Ex d TECH PVT. LTD. CHENNAI-600 032.				
DRAWN	SM					
CHECKED	DKK					
APPROVED	GK					
SCALE	NTS	FILE REF. TL/169	CAT No. TL/OA/169	GA.DRG.No. SCG/OF0000/TL169/0001	REV 0	DATE 14/11/05